




Date : 2025-08-15

CERTIFICATE OF COMPLIANCE

This Certificate of Compliance Validates the Following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	EX26659-20160326 EX26659-20160327	CERTIFICATE NUMBER	GMFZ.EX26659
DATE OF ISSUE	20160326 20160326	DATE OF ISSUE	2024-12-06
DATE OF EXPIRY	Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service.	DATE OF EXPIRY	Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service.
Manufacturer Details			
NAME OF FACTORY / MANUFACTURER	Cease Fire®	NAME OF THE BRAND	Cease Fire®
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	9321 NE 72nd Ave Suite D Vancouver, WA 98665	MODEL / NO	See pages 9-13 for model information.
WEBSITE	www.ceasefire.com	LOGO ON THE PRODUCT	
TEL	360-567-0990	EMAIL	mike@ceasefire.com



Product Details From Test Report		Reference Test Report page NO
DESCRIPTION OF THE PRODUCT <small>(TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)</small>	<p>Self-contained Automatic Extinguisher Units</p> <p>This category covers fixed extinguisher units having integral automatically operated thermal fire detection. The fire-extinguishing classifications of these extinguisher units are developed at ambient room temperature (approximately 70°F) and may be reduced at lower temperature. These units are intended to be installed and maintained in accordance with the Listee's installation and maintenance manual dated as specified in the individual certifications. Copies of the manual can be obtained from the Listee.</p>	<p>EX26659-20160326</p> <p>EX26659-20160327</p>
	<p>ANSI/CAN/UL/ULC 2166 - Halocarbon Clean Agent Extinguishing System Units.</p> <p>1 Scope</p> <p>1.1 These requirements cover the construction and operation of halocarbon clean agent fire extinguishing system units intended to be installed, inspected, tested, and maintained in accordance with the Standard on Clean Agent Fire Extinguishing Systems, NFPA 2001 and with the National Fire Code of Canada.</p> <p>1.2 These requirements also cover halocarbon clean agent automatic extinguisher units that may have a manual means of operation, and are intended to be used in accordance with the manufacturer's installation instructions. Automatic extinguisher units are not intended:</p> <p>a) For use as a general substitute for pre-engineered or engineered clean agent extinguishing system units; or</p> <p>b) For protection of fire risks larger than those specified in the manufacturer's instructions for a single unit by using multiple units.</p>	<p>EX26659-20160326</p> <p>EX26659-20160327</p>
TEST STANDARD <small>(SUCH AS ASTM/BS EN/ DN ETC)</small>		



TEST DESCRIPTION	The following tests from the referenced standard, as applicable to the products submitted, were conducted:			EX26659-20160326 EX26659-20160327
	Standard No.	Test	Sec.	
	UL 1254	Fire Test – Total Flooding Protection System	Sec. 26	
	UL 1254	Fire Test – Class B Local Application Protection System	Sec. 27	
	UL 1254	Fire Test – Automobile Service Station Fueling Area Protection System	Sec. 28	
	UL 1254	Fire Test – Open-Face Paint Spray Booth Protection System	Sec. 29	
	UL 1254	Fire Test – Vehicle Paint Spray Booth Protection System	Sec. 30	
	UL 1254	Fire Test and Appliance Slash Test – Commercial Cooking Equipment Protection System	Sec. 31	
	UL 1254	Flow Distribution Tests	Sec. 32	
	UL 1254	Hydrostatic Strength - components	Sec. 33.2	
	UL 1254	Hydrostatic Strength – DOT cylinders	Sec. 33.1	
	UL 1254	30-Day Elevated Temperature	Sec. 34	



	UL 1254	Temperature Cycling	Sec. 35
	UL 1254	Salt Spray Corrosion	Sec. 36
	UL 1254	Wet Chemical Extinguishing Agent Exposure Test for Metallic Parts	Sec. 37
	UL 1254	500 Cycle Operation	Sec. 38
	UL 1254	One-Year Time Leakage	Sec. 39
	UL 1254	Mounting Device	Sec. 40
	UL 1254	Flexible Hose Low Temperature Test	Sec. 41
	UL 1254	Flexible Hose Cycling Test	Sec. 42
	UL 1254	Flexible Hose Fire Exposure Test	Sec. 43
	UL 1254	Operation of Manual Actuators and Manual Pull Stations	Sec. 44
	UL 1254	Pneumatic Operation	Sec. 45
	UL 1254	Pressure Relief Burst (Pressure)	Sec. 46
	UL 1254	Pressure Relief Burst (Flow Capacity)	Sec. 46
	UL 1254	Vibration and Shock Resistance Test	Sec. 47
	UL 1254	Elastomeric Parts	Sec. 48
	UL 1254	Moist Ammonia	Sec. 49
	UL 1254	Aging Tests – Plastic Materials	Sec. 50
	UL 1254	Dry Chemical Extinguishing Agent Tests	Sec. 51
	UL 1254	Wet Chemical Extinguishing Agent Tests	Sec. 52



	UL 1254	Calibration Test – Gauges	Sec. 53
	UL 1254	Burst Strength Test – Gauges	Sec. 54
	UL 1254	Overpressure Test – Gauges	Sec. 55
	UL 1254	Impulse Test – Gauges	Sec. 56
	UL 1254	Pressure Gauge Relief Test	Sec. 57
The results of this investigation including evaluation and testing indicate that the products are complied with applicable requirements of the Standard UL 1254, “Pre-Engineered and Engineered Dry and Pre-Engineered Wet Chemical Extinguishing System Units”. Therefore, such products are judged eligible to bear UL's Mark.			
SPECIFICATION OF TEST SPECIMEN	The samples used for testing and evaluation were considered representative of the submitted products		EX26659-20160326 EX26659-20160327
TEST RESULT (SUCH AS PASSED CRITERIA___/ COMPLIED TO___/ DURATION___/OBSERVATION___/ETC)	Pass – Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service		EX26659-20160326 EX26659-20160327
PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN___/TO BE INSTALLED AT___/TO BE CONNECTED WITH___/TO BE INSTALLED WITH___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN___/NOT TO BE INSTALLED AT___/ NOT TO BE INSTALLED WITH___ ETC.	This category covers fixed extinguisher units having integral automatically operated thermal fire detection. The fire-extinguishing classifications of these extinguisher units are developed at ambient room temperature (approximately 70°F) and may be reduced at lower temperature. These units are intended to be installed and maintained in accordance with the Listee's installation and maintenance manual dated as specified in the individual certifications. Copies of the manual can be obtained from the Listee. Authorities Having Jurisdiction should be consulted as to the acceptability for particular hazards and requirements covering installation.		EX26659-20160326 EX26659-20160327





Laboratory and Certification Body Details			
NAME OF CERTIFICATION BODY	UL LLC	NAME OF TEST FACILITY	UL LLC CEASE FIRE PSI
CERTIFICATION BODY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	333 Pfingsten Road, Northbrook, IL, USA	TEST FACILITY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	333 Pfingsten Road, Northbrook, IL, USA 9321 NE 72nd Ave, Bldg D, Suite 12 Vancouver, WA, 98662, US 6032 N. Cutter Circle, Suite 480 Portland, OR 97217
WEBSITE	www.ul.com	WEBSITE	www.ul.com
TEL	+1-877-854-3577	TEL	+1-877-854-3577
EMAIL	FireandSecurity@ul.com	EMAIL	FireandSecurity@ul.com
ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	American National Standards Institute (ANSI) as a product certification body ansi.org	ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	International Accreditation Services (IAS) iasonline.org
AS PER (STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	ISO/IEC 17065	AS PER (STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)	ISO 17065
VALIDITY (EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)	Active as of date of issuance of this certificate	VALIDITY (EXPIRY DATE OF LABORATORY ACCREDITATION)	Active as of date of issuance of this certificate
REFERENCE NUMBER: (CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	Accreditation ID #0198	REFERENCE NUMBER: (THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	Accreditation ID # TL-157
CERTIFICATION MARK			



(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	Cody Kitterman	SIGNATURE	
EMAIL / TEL	cody@ceasefire.com 360-567-0990	FACTORY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	Kevin Holly	SIGNATURE	
EMAIL / TEL	Kevin.hollyjr@ul.com	CERTIFICATION BODY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate			

ATTACHMENTS:

- COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)



MODELS:

Model CFP96

Agent	Agent Capacity	Max Protection Area, ft2 (m2)	Max Protection Volume, ft3 (m3)	Max Hazard Length, ft (m) any side	Min/Max Ceiling Height, ft (m)	Rating	Storage Temperature Range	Date of Installation Manual (Date of Supplement)
CF-33	1.5 lbs (0.68 kg)	16 ft2 (1.49 m2)	--	4 ft (1.22 m)	No Min / 5 ft (1.52 m) Max	A:B:C	-20°F to 120°F (-28.9 to 49°C)	6/1/2017

Model CFP88LP

Agent	Agent Capacity	Max Protection Area, ft2 (m2)	Max Protection Volume, ft3 (m3)	Max Hazard Length, ft (m) any side	Min/Max Ceiling Height, ft (m)	Rating	Storage Temperature Range	Date of Installation Manual (Date of Supplement)
CF-33	1.5 lbs (0.68 kg)	11 ft2 (1.02 m2)	88 ft3 (4.29 m3)	4 ft (1.22 m)	No Min / 8 ft (2.44 m) Max	A:B:C	-20°F to 120°F (-28.9 to 49°C)	8/17/2023

Model CFP6750

Agent	Agent Capacity	Max Protection Area, ft2 (m2)	Max Protection Volume, ft3 (m3)	Max Hazard Length, ft (m) any side	Min/Max Ceiling Height, ft (m)	Rating	Storage Temperature Range	Date of Installation Manual (Date of Supplement)
CF-33	50 lbs (22.68 kg)	225 ft2 (20.90 m2)	--	15 ft (4.57 m)	No Min / 30 ft (9.14 m) Max	A:B:C	-20°F to 120°F (-28.9 to 49°C)	2/1/2016



MODELS (CONTINUED):

Model CFP640LP

Agent	Agent Capacity	Max Protection Area, ft2 (m2)	Max Protection Volume, ft3 (m3)	Max Hazard Length, ft (m) any side	Min/Max Ceiling Height, ft (m)	Rating	Storage Temperature Range	Date of Installation Manual (Date of Supplement)
CF-33	7.0 lbs (3.18kg)	67 ft2 (6.22 m2)	672.4 ft3 (19.04 m3)	8.2 ft (2.49 m)	No Min / 10 ft (3.05 m) Max	A:B:C	-20°F to 120°F (-28.9 to 49°C)	6/20/2023

Model CFP640

Agent	Agent Capacity	Max Protection Area, ft2 (m2)	Max Protection Volume, ft3 (m3)	Max Hazard Length, ft (m) any side	Min/Max Ceiling Height, ft (m)	Rating	Storage Temperature Range	Date of Installation Manual (Date of Supplement)
CF-33	7.0 lbs (3.18kg)	67 ft2 (6.22 m2)	672.4 ft3 (19.04 m3)	8.2 ft (2.49 m)	No Min / 10 ft (3.05 m) Max	A:B:C	-20°F to 120°F (-28.9 to 49°C)	6/20/2023

Model CFP3375LP

Agent	Agent Capacity	Max Protection Area, ft2 (m2)	Max Protection Volume, ft3 (m3)	Max Hazard Length, ft (m) any side	Min/Max Ceiling Height, ft (m)	Rating	Storage Temperature Range	Date of Installation Manual (Date of Supplement)
CF-33	50 lbs (22.68 kg)	225 ft2 (20.90 m2)	--	15 ft (4.57 m)	No Min / 15 ft (4.57 m) Max	A:B:C	-20°F to 120°F (-28.9 to 49°C)	11/1/2023



MODELS (CONTINUED):

Model CFP3375

Agent	Agent Capacity	Max Protection Area, ft2 (m2)	Max Protection Volume, ft3 (m3)	Max Hazard Length, ft (m) any side	Min/Max Ceiling Height, ft (m)	Rating	Storage Temperature Range	Date of Installation Manual (Date of Supplement)
CF-33	30 lbs (13.61 kg)	225 ft2 (20.90 m2)	--	15 ft (4.57 m)	No Min / 15 ft (4.57 m) Max	A:B:C	-20°F to 120°F (-28.9 to 49°C)	2/1/2016

Model CFP1700

Agent	Agent Capacity	Max Protection Area, ft2 (m2)	Max Protection Volume, ft3 (m3)	Max Hazard Length, ft (m) any side	Min/Max Ceiling Height, ft (m)	Rating	Storage Temperature Range	Date of Installation Manual (Date of Supplement)
CF-33	15 lbs (6.8 kg)	132.25 ft2 (12.29 m2)	--	11.5 ft (3.51 m)	No Min / 13 ft (3.96 m) Max	A:B:C	-20°F to 120°F (-28.9 to 49°C)	2/1/2016

Model CFP1300LP

Agent	Agent Capacity	Max Protection Area, ft2 (m2)	Max Protection Volume, ft3 (m3)	Max Hazard Length, ft (m) any side	Min/Max Ceiling Height, ft (m)	Rating	Storage Temperature Range	Date of Installation Manual (Date of Supplement)
CF-33	15 lbs (6.8 kg)	100 ft2 (9.29 m2)	1300 ft3 (396.24 m3)	10 ft (3.05 m)	No Min / 13 ft (3.96 m) Max	A:B:C	-20°F to 120°F (-28.9 to 49°C)	8/17/2023



MODELS (CONTINUED):

Model CFP1300

Agent	Agent Capacity	Max Protection Area, ft ² (m ²)	Max Protection Volume, ft ³ (m ³)	Max Hazard Length, ft (m) any side	Min/Max Ceiling Height, ft (m)	Rating	Storage Temperature Range	Date of Installation Manual (Date of Supplement)
CF-33	10 lbs (4.54 kg)	100 ft ² (9.29 m ²)	--	10 ft (3.05 m)	No Min / 13 ft (3.96 m) Max	A:B:C	-20°F to 120°F (-28.9 to 49°C)	2/1/2016

Model CFP128LP

Agent	Agent Capacity	Max Protection Area, ft ² (m ²)	Max Protection Volume, ft ³ (m ³)	Max Hazard Length, ft (m) any side	Min/Max Ceiling Height, ft (m)	Rating	Storage Temperature Range	Date of Installation Manual (Date of Supplement)
CF-33	8 lbs (3.63 kg)	16 ft ² (1.49 m ²)	128 ft ³ (3.63 m ³)	4 ft (1.22 m)	No Min / 8 ft (2.44 m) Max	A:B:C	-20°F to 120°F (-28.9 to 49°C)	8/17/2023

Model CFF800LP

Agent	Agent Capacity	Max Protection Area, ft ² (m ²)	Max Protection Volume, ft ³ (m ³)	Max Hazard Length, ft (m) any side	Min/Max Ceiling Height, ft (m)	Rating	Storage Temperature Range	Date of Installation Manual (Date of Supplement)
CF-33 with supplemental HFC-227ea pressurizing gas	7/9 lbs (3.18/4.08 kg)	67.24 ft ² (6.25 m ²)	--	8.2 ft (2.5 m)	No Min / 12.2 ft (3.72 m) Max	A:B:C	32°F to 120°F (0 to 49°C)	3/31/2015



MODELS (CONTINUED):

Model CFF800

Agent	Agent Capacity	Max Protection Area, ft2 (m2)	Max Protection Volume, ft3 (m3)	Max Hazard Length, ft (m) any side	Min/Max Ceiling Height, ft (m)	Rating	Storage Temperature Range	Date of Installation Manual (Date of Supplement)
CF-33 with supplemental HFC-227ea pressurizing gas	7/9 lbs (3.18/4.08 kg)	67.24 ft2 (6.25 m2)	--	8.2 ft (2.5 m)	No Min / 12.2 ft (3.72 m) Max	A:B:C	32°F to 120°F (0 to 49°C)	3/31/2015

Model CFF1330LP

Agent	Agent Capacity	Max Protection Area, ft2 (m2)	Max Protection Volume, ft3 (m3)	Max Hazard Length, ft (m) any side	Min/Max Ceiling Height, ft (m)	Rating	Storage Temperature Range	Date of Installation Manual (Date of Supplement)
CF-33 with supplemental HFC-227ea pressurizing gas	22/28 lbs (9.98/12.70 kg)	121 ft2 (11.24 m2)	1331 ft3 (37.6 m3)	11 ft (3.35 m)	No Min / 11ft (3.35 m) Max	A:B:C	32°F to 120°F (0 to 49°C)	8/17/2023